

FIRE COMMISSION
City and County of San Francisco
London N. Breed, Mayor

Stephen A. Nakajo, *President*
Francee Covington, *Vice President*
Michael Hardeman, *Commissioner*
Ken Cleaveland, *Commissioner*
Joe Alioto Veronese, *Commissioner*



698 Second Street
San Francisco, CA 94107
Telephone 415.558.3451
Fax 415.558.3413
Maureen Conefrey, *Secretary*

September 11, 2019

Honorable Garrett L. Wong
Presiding Judge of the Superior Court
400 McAllister Street, Room 008
San Francisco, CA 94102-4512

Dear Honorable Garrett L. Wong,

Pursuant to the request of Mr. Rasha Harvey, Foreperson of the 2018-2019 Civil Grand Jury, the Fire Commission is submitting the attached response to the Civil Grand Jury's report, dated July 17, 2019 and titled "Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System." Please do not hesitate to call if you have any questions or concerns regarding our response.

Thank you for your attention to this matter

Sincerely,

A handwritten signature in cursive script that reads "Maureen Conefrey for:". The signature is written in dark ink and is positioned above the printed name of the signatory.

Stephen A. Nakajo
President, San Francisco Fire Commission

cc: Clerk of the Board, Government Audit and Oversight Committee
Mr. Rasha Harvey, Foreperson 2018-2019 Civil Grand Jury
Fire Commissioners
Jeanine R. Nicholson, Chief of Department

Report Title (Publication Date)	F#	Finding (text may be duplicated due to spanning and multiple respondent effects)	Respondent Assigned by CGJ (Response Due Date)	Finding Response (Agree/Disagree)	Finding Response Text	R# (for F#)	Recommendation (text may be duplicated due to spanning and multiple respondent effects)	Respondent Assigned by CGJ (Response Due Date)	Recommendation Response (Implementation)	Recommendation Response Text
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System (July 27, 2019)	F1	Fires resulting from an earthquake represent a significant risk of widespread damage and potential loss of life in San Francisco.	President, San Francisco Fire Commission (September 15, 2019)	Agree with the finding		R1 (for F1-6)	By no later than December 31, 2020, the Mayor, the SFPUC, the SFFD, and the Office of Resilience and Capital Planning should jointly present to the Board of Supervisors a detailed plan to ensure the City is well prepared to fight fires in all parts of San Francisco in the event of a 1906-magnitude (7.8) earthquake.	President, San Francisco Fire Commission (September 15, 2019)	Will be implemented	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System (July 27, 2019)	F1	Fires resulting from an earthquake represent a significant risk of widespread damage and potential loss of life in San Francisco.	President, San Francisco Fire Commission (September 15, 2019)	Agree with the finding		R2 (for F1-6)	The plan discussed in Recommendation R1 should include a detailed proposal, including financing sources, for the installation within 15 years of a high-pressure, multi-sourced, seismically safe emergency water system for those parts of the City that don't currently have one, i.e., by no later than June 30, 2034.	President, San Francisco Fire Commission (September 15, 2019)	Requires further analysis	The commitment of sources for specific uses on specific timelines for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of step with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System (July 27, 2019)	F2	The municipal water supply system (MWSS) is highly vulnerable to damage from a major earthquake and is not a reliable source for water supply for firefighting after a major earthquake.	President, San Francisco Fire Commission (September 15, 2019)	Disagree, partially	The MWSS has been significantly upgraded in the last 15 years through the Water Supply Improvement Program (WSIP) initiated by the SFPUC. The goals of WSIP included to reduce vulnerability of the water system to damage from earthquakes and increase overall water system reliability. There were 35 in-city projects within the \$4.8 billion-dollar program. The WSIP was the largest capital program ever undertaken by San Francisco, and one of the largest water infrastructure programs in the nation. Additionally, it is one of the only comprehensive and strategic infrastructure programs targeted specifically at improving a water system's seismic reliability and resiliency. Additionally, it is unique because the WSIP utilized a 7.8 magnitude earthquake as its seismic Level of Service.	R1 (for F1-6)	By no later than December 31, 2020, the Mayor, the SFPUC, the SFFD, and the Office of Resilience and Capital Planning should jointly present to the Board of Supervisors a detailed plan to ensure the City is well prepared to fight fires in all parts of San Francisco in the event of a 1906-magnitude (7.8) earthquake.	President, San Francisco Fire Commission (September 15, 2019)	Will be implemented	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System (July 27, 2019)	F2	The municipal water supply system (MWSS) is highly vulnerable to damage from a major earthquake and is not a reliable source for water supply for firefighting after a major earthquake.	President, San Francisco Fire Commission (September 15, 2019)	Disagree, partially	The MWSS has been significantly upgraded in the last 15 years through the Water Supply Improvement Program (WSIP) initiated by the SFPUC. The goals of WSIP included to reduce vulnerability of the water system to damage from earthquakes and increase overall water system reliability. There were 35 in-city projects within the \$4.8 billion-dollar program. The WSIP was the largest capital program ever undertaken by San Francisco, and one of the largest water infrastructure programs in the nation. Additionally, it is one of the only comprehensive and strategic infrastructure programs targeted specifically at improving a water system's seismic reliability and resiliency. Additionally, it is unique because the WSIP utilized a 7.8 magnitude earthquake as its seismic Level of Service.	R2 (for F1-6)	The plan discussed in Recommendation R1 should include a detailed proposal, including financing sources, for the installation within 15 years of a high-pressure, multi-sourced, seismically safe emergency water system for those parts of the City that don't currently have one, i.e., by no later than June 30, 2034.	President, San Francisco Fire Commission (September 15, 2019)	Requires further analysis	The commitment of sources for specific uses on specific timelines for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of step with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.

2018-2019 CIVIL GRAND JURY FINDINGS, RECOMMENDATIONS, AND RESPONSES TO FINDINGS AND RECOMMENDATIONS

Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F3	Approximately 30 cisterns have recently been added with funds from ESER bonds, but cisterns only have up to about an hour of water supply and thus do not provide sufficient water for fighting fires following a major earthquake.	President, San Francisco Fire Commission [September 15, 2019]	Agree with the finding	Cisterns serve as one of many important tools for use by the SFD in response to a disaster. Cistern locations are strategically located in the City in the event of a major conflagration to assist as a "Demarcation Line" on some of the City's major thoroughfares. This was realized after the 1906 earthquake. With work accomplished through the ESER bond program, cisterns have been seismically improved throughout the City and the overall number of cisterns has increased to approximately 230, providing the Fire Department access to millions of gallons of water in an emergency.	R1 [for F1-F6]	By no later than December 31, 2020, the Mayor, the SFPUC, the SFD, and the Office of Resilience and Capital Planning should jointly present to the Board of Supervisors a detailed plan to ensure the City is well prepared to fight fires in all parts of San Francisco in the event of a 1906-magnitude (7.8) earthquake.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F3	Approximately 30 cisterns have recently been added with funds from ESER bonds, but cisterns only have up to about an hour of water supply and thus do not provide sufficient water for fighting fires following a major earthquake.	President, San Francisco Fire Commission [September 15, 2019]	Agree with the finding	Cisterns serve as one of many important tools for use by the SFD in response to a disaster. Cistern locations are strategically located in the City in the event of a major conflagration to assist as a "Demarcation Line" on some of the City's major thoroughfares. This was realized after the 1906 earthquake. With work accomplished through the ESER bond program, cisterns have been seismically improved throughout the City and the overall number of cisterns has increased to approximately 230, providing the Fire Department access to millions of gallons of water in an emergency.	R2 [for F1-F6]	The plan discussed in Recommendation R1 should include a detailed proposal, including financing sources, for the installation within 15 years of a high-pressure, multi-sourced, seismically safe emergency water system for those parts of the City that don't currently have one, i.e., by no later than June 30, 2034.	President, San Francisco Fire Commission [September 15, 2019]	Requires further analysis	The commitment of sources for specific uses on specific timelines for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of sync with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F4	The City's high-pressure emergency water supply system, known as the Auxiliary Water Supply System (AWSS), does not cover large parts of Supervisory Districts 1, 4, 7 and 11, roughly one-third of the City's developed area. As a result, these districts are not adequately protected from fires after a major earthquake.	President, San Francisco Fire Commission [September 15, 2019]	Agree with the finding	The SFPUC, SFD, and San Francisco Public Works (SFPW) are committed to increasing fire protection throughout San Francisco. Since the passage of the first Earthquake Safety and Emergency Response Bond in 2010, the three agencies have been implementing projects to improve the AWSS system's seismic reliability and range of coverage. Enhancing the AWSS range of coverage to all areas of the City would require the allocation of funds to do so. The three agencies will continue to develop and implement projects utilizing new and proven technologies that improve upon the original system design. There have been many advancements in earthquake resistant pipeline design and materials, hydrants, and seismic valves since the early 1900s, and the City intends to use the best possible technology available to meet the performance standards of the SFD.	R1 [for F1-F6]	By no later than December 31, 2020, the Mayor, the SFPUC, the SFD, and the Office of Resilience and Capital Planning should jointly present to the Board of Supervisors a detailed plan to ensure the City is well prepared to fight fires in all parts of San Francisco in the event of a 1906-magnitude (7.8) earthquake.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F4	The City's high-pressure emergency water supply system, known as the Auxiliary Water Supply System (AWSS), does not cover large parts of Supervisory Districts 1, 4, 7 and 11, roughly one-third of the City's developed area. As a result, these districts are not adequately protected from fires after a major earthquake.	President, San Francisco Fire Commission [September 15, 2019]	Agree with the finding	The SFPUC, SFD, and San Francisco Public Works (SFPW) are committed to increasing fire protection throughout San Francisco. Since the passage of the first Earthquake Safety and Emergency Response Bond in 2010, the three agencies have been implementing projects to improve the AWSS system's seismic reliability and range of coverage. Enhancing the AWSS range of coverage to all areas of the City would require the allocation of funds to do so. The three agencies will continue to develop and implement projects utilizing new and proven technologies that improve upon the original system design. There have been many advancements in earthquake resistant pipeline design and materials, hydrants, and seismic valves since the early 1900s, and the City intends to use the best possible technology available to meet the performance standards of the SFD.	R2 [for F1-F6]	The plan discussed in Recommendation R1 should include a detailed proposal, including financing sources, for the installation within 15 years of a high-pressure, multi-sourced, seismically safe emergency water system for those parts of the City that don't currently have one, i.e., by no later than June 30, 2034.	President, San Francisco Fire Commission [September 15, 2019]	Requires further analysis	The commitment of sources for specific uses on specific timelines for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of sync with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.

2018-2019 CIVIL GRAND JURY FINDINGS, RECOMMENDATIONS, AND RESPONSES TO FINDINGS AND RECOMMENDATIONS

Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F4	The City's high-pressure emergency water supply system, known as the Auxiliary Water Supply System (AWSS), does not cover large parts of one-third of the City's developed area. As a result, these districts are not adequately protected from fires after a major earthquake.	Agree with the finding	President, San Francisco Fire Commission [September 15, 2019]	As the City considers what is essential to protect San Francisco, it is important to acknowledge our multiple, complex resilience challenges. These challenges are documented in the Resilient SF Strategy (2016) and underlie the strategic efforts of our capital investments as represented in the 10-Year Capital Plan (last updated 2019). These challenges are: Earthquakes, Sea Level Rise/Climate Change, Aging Infrastructure, Unaffordability, and Social Inequity. All of these challenges represent meaningful threats to San Franciscans, their property, and their ability to make a life in the city. In making decisions about priority investments, San Francisco must keep an eye on all of these challenges, identify the areas of greatest need across them, and make progress on all fronts simultaneously. The City has taken significant steps since 2010 to ensure that the City has a high-pressure multi-sourced, seismically safe EFWS. Since the passage of the first Earthquake Safety and Emergency Response Bond in 2010, SFPUC, SFPD, SF Public Works have been implementing projects to improve the system's seismic reliability and range of coverage. The three agencies will continue to implement projects utilizing new and proven technologies that improve upon the original system design.	R5 [for F4]	The SFPUC, SFPD, and San Francisco Public Works (SFPW) are committed to increasing fire protection throughout San Francisco. Since the passage of the first Earthquake Safety and Emergency Response Bond in 2010, the three agencies have been implementing projects to improve the AWSS system's seismic reliability and range of coverage. Enhancing the AWSS system's coverage to all areas of the City would require the allocation of funds to do so. The three agencies will continue to develop and implement projects utilizing new and proven technologies that improve upon the original system design. There have been many advancements in earthquake resistant pipeline design and materials, hydrants, and seismic valves since the early 1900s, and the City intends to use the best possible technology available to meet the performance standards of the SFPD.	The SFPD should strategically locate the majority of the PWS hose tenders in areas that at present only have low-pressure hydrants and/or cisterns.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	The Department is currently finalizing specifications for these units, after which they will go out to bid through the City's procurement processes before construction. It is anticipated the Department will take receipt of these units in the second half of 2020/early 2021. These hose tenders are a heavy-duty apparatus designed to be able to be deployed and moved throughout the City depending on need, giving the Department needed operational flexibility in its response.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F5	A high-pressure, multi-sourced, seismically safe emergency firefighting water supply will be costly but is essential to protect the City.	Agree with the finding	President, San Francisco Fire Commission [September 15, 2019]	As the City considers what is essential to protect San Francisco, it is important to acknowledge our multiple, complex resilience challenges. These challenges are documented in the Resilient SF Strategy (2016) and underlie the strategic efforts of our capital investments as represented in the 10-Year Capital Plan (last updated 2019). These challenges are: Earthquakes, Sea Level Rise/Climate Change, Aging Infrastructure, Unaffordability, and Social Inequity. All of these challenges represent meaningful threats to San Franciscans, their property, and their ability to make a life in the city. In making decisions about priority investments, San Francisco must keep an eye on all of these challenges, identify the areas of greatest need across them, and make progress on all fronts simultaneously. The City has taken significant steps since 2010 to ensure that the City has a high-pressure multi-sourced, seismically safe EFWS. Since the passage of the first Earthquake Safety and Emergency Response Bond in 2010, SFPUC, SFPD, SF Public Works have been implementing projects to improve the system's seismic reliability and range of coverage. The three agencies will continue to implement projects utilizing new and proven technologies that improve upon the original system design.	R1 [for F1-F6]	By no later than December 31, 2020, the Mayor, the SFPUC, the SFPD, and the Office of Resilience and Capital Planning should jointly present to the Board of Supervisors a detailed plan to ensure the City is well prepared to fight fires in all parts of San Francisco in the event of a 1906-magnitude (7.8) earthquake.	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F5	A high-pressure, multi-sourced, seismically safe emergency firefighting water supply will be costly but is essential to protect the City.	Agree with the finding	President, San Francisco Fire Commission [September 15, 2019]	As the City considers what is essential to protect San Francisco, it is important to acknowledge our multiple, complex resilience challenges. These challenges are documented in the Resilient SF Strategy (2016) and underlie the strategic efforts of our capital investments as represented in the 10-Year Capital Plan (last updated 2019). These challenges are: Earthquakes, Sea Level Rise/Climate Change, Aging Infrastructure, Unaffordability, and Social Inequity. All of these challenges represent meaningful threats to San Franciscans, their property, and their ability to make a life in the city. In making decisions about priority investments, San Francisco must keep an eye on all of these challenges, identify the areas of greatest need across them, and make progress on all fronts simultaneously. The City has taken significant steps since 2010 to ensure that the City has a high-pressure multi-sourced, seismically safe EFWS. Since the passage of the first Earthquake Safety and Emergency Response Bond in 2010, SFPUC, SFPD, SF Public Works have been implementing projects to improve the system's seismic reliability and range of coverage. The three agencies will continue to implement projects utilizing new and proven technologies that improve upon the original system design.	R2 [for F1-F6]	The plan discussed in Recommendation R1 should include a detailed proposal, including financing sources, for the installation within 15 years of a high-pressure, multi-sourced, seismically safe emergency water system for those parts of the City that don't currently have one, i.e., by no later than June 30, 2034.	The commitment of sources for specific use on specific timeline for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of step with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.	President, San Francisco Fire Commission [September 15, 2019]	Requires further analysis	The commitment of sources for specific use on specific timeline for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of step with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F6	Unless the City increases funding levels, it will be several decades (i.e., after the USGS predicts one or more major earthquakes will occur) before the southern parts of the City have a high-pressure, multi-sourced, seismically safe emergency firefighting water supply.	Disagree, wholly	President, San Francisco Fire Commission [September 15, 2019]	Decisions about programming and funding levels of future ESER bonds and other complementary sources that could support the expansion of the AWSS have yet to be made.	R1 [for F1-F6]	By no later than December 31, 2020, the Mayor, the SFPUC, the SFPD, and the Office of Resilience and Capital Planning should jointly present to the Board of Supervisors a detailed plan to ensure the City is well prepared to fight fires in all parts of San Francisco in the event of a 1906-magnitude (7.8) earthquake.	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	Ensuring that San Francisco has the infrastructure and resources to be well prepared to fight fires in all parts of San Francisco is something that will be a focus of the next 10-Year Capital Plan. Per Administrative Code 3.20, that Plan must be submitted to the Mayor and Board no later than March 1 of each odd-numbered year for approval no later than May 1. The requested presentation would be delivered as part of that Plan's submission to enable holistic planning across San Francisco's resilience challenges. Updates available on this timeline would be included. The City cannot discuss the project and timeline until the ESER 2020 plan passes. For this reason, the City will sync this recommendation with the Capital Plan, and push back the timeline to December 31, 2021.

2018-2019 CIVIL GRAND JURY FINDINGS, RECOMMENDATIONS, AND RESPONSES TO FINDINGS AND RECOMMENDATIONS

Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F6	Unless the City increases funding levels, it will be several decades (i.e., after the USGS predicts one or more major earthquakes will occur) before the southern parts of the City have a high pressure, multi-sourced, seismically safe emergency firefighting water supply.	President, San Francisco Fire Commission [September 15, 2019]	Disagree, wholly	Decisions about programming and funding levels of future ESER bonds and other complementary sources that could support the expansion of the AWSS have yet to be made.	R2 [for F1-F6]	The plan discussed in Recommendation R1 should include a detailed proposal, including financing sources, for the installation within 15 years of a high-pressure, multi-sourced, seismically safe emergency water system for those parts of the City that don't currently have one, i.e., by no later than June 30, 2034.	President, San Francisco Fire Commission [September 15, 2019]	Requires further analysis	The commitment of sources for specific uses on specific timelines for San Francisco's public infrastructure is the work of the 10-Year Capital Plan. The plan discussed in Recommendation 1 will be acknowledged in the Capital Plan, and based on analysis, will be done on the capital plan timeline. The capital planning process gathers, documents, and balances planned funding for needs across the public infrastructure portfolio and across San Francisco's resilience challenges. The Capital Plan has longstanding funding principles to guide the prioritization of public infrastructure investments. These investments are tiered: (1) address legal and/or regulatory mandates; (2) ensure public safety and enhance resilience; (3) preserve assets and promote sustainability; (4) advance planned and programmatic needs; and (5) promote economic development. In the next 10-Year Capital Plan and those that follow, the City will continue to analyze priority projects and programs and identify sources to advance those priorities. Committing to entirely funding a single program out of context and without regard for the trade-offs of that commitment would be out of step with the City's longstanding and highly regarded capital planning process and likely create significant vulnerabilities elsewhere in the portfolio.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F6	Unless the City increases funding levels, it will be several decades (i.e., after the USGS predicts one or more major earthquakes will occur) before the southern parts of the City have a high pressure, multi-sourced, seismically safe emergency firefighting water supply.	President, San Francisco Fire Commission [September 15, 2019]	Disagree, wholly	Decisions about programming and funding levels of future ESER bonds and other complementary sources that could support the expansion of the AWSS have yet to be made.	R4 [for F6-F7]	As interim measure, by no later than June 30, 2021, the City should purchase the 20 new PWSS hose tenders being requested by the SFFD, to replace and expand its currently inadequate inventory.	President, San Francisco Fire Commission [September 15, 2019]	Requires further analysis	The Fire Department has been allocated funding to purchase five units through funds from the FY19-20 City budget and an allocation from the State. The Department is currently working with the Office of Contract Administration to develop a multi-year term contract for hose tenders so in the case that additional funding is secured in future years, the Department will be able to reduce the amount of time for procurement of the apparatus. Each hose tender cost \$1 million each, and we need to weigh purchase of additional hose tenders to other budget request and priority.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F7	The existing Portable Water Supply System (PWSS) inventory is inadequate. Investing in more PWSS hose tenders would provide a relatively quick, cost-effective interim means to improve protection of the southern and western parts of the City until a high-pressure, multi-sourced, seismically safe emergency water supply can be developed in those areas.	President, San Francisco Fire Commission [September 15, 2019]	Agree with the finding	The Fire Department has been allocated funding to purchase five units through funds from the FY19-20 City budget and an allocation from the State. While the Department currently has five older hose tenders spread-out throughout the City, these new units are much more modern and provide the Department with a number of operational benefits, including the following: the capability of pumping and drafting water from any water source; extending the current AWSS system infrastructure; carrying 6,000 feet of hose for deployment; a 5,500 gallon per minute (GPM) on-board water pump and a 3,000 GPM portable submersible water pump; on-board monitor with a 525 foot reach; and four wheel drive. In addition, the Department has been successful in advocating and receiving Federal grant funds to assist with purchasing various PWSS equipment (valves, hose, ramps, etc.), and will continue to advocate for alternative sources of funding to increase the inventory of PWSS equipment.	R4 [for F6-F7]	As interim measure, by no later than June 30, 2021, the City should purchase the 20 new PWSS hose tenders being requested by the SFFD, to replace and expand its currently inadequate inventory.	President, San Francisco Fire Commission [September 15, 2019]	Requires further analysis	The Fire Department has been allocated funding to purchase five units through funds from the FY19-20 City budget and an allocation from the State. The Department is currently working with the Office of Contract Administration to develop a multi-year term contract for hose tenders so in the case that additional funding is secured in future years, the Department will be able to reduce the amount of time for procurement of the apparatus. Each hose tender cost \$1 million each, and we need to weigh purchase of additional hose tenders to other budget request and priority.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F8	Redundancy is an important feature of an emergency firefighting water system.	President, San Francisco Fire Commission [September 15, 2019]	Agree with the finding		R6 [for F8-F9]	The SFPUC, the SFFD and the SF Department of the Environment should study adding salt-water pump stations to improve the redundancy of water sources, especially on the west side. Findings and recommendations from this study should be presented to the Board of Supervisors by no later than June 30, 2021.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	SFPUC and SFFD will complete this study by June 30, 2021.

Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F9	Current plans to extend protections to the western part of the City do not include any high-pressure water sources north of Golden Gate Park.	Disagree, partially	President, San Francisco Fire Commission [September 15, 2019]	While it is true that the SPUC and SFD are studying four potential water sources proposed to supply a potable EFWS on the west side of the City, which are not located north of Golden Gate Park, which by no means would reduce the proposed system's resiliency, reliability, performance, or ability to provide abundant high-pressure water for fire suppression to the Richmond District after a seismic event, San Francisco is unique in that there are 11 in-city reservoirs, with a total water capacity of approximately 413,000,000 gallons. Additionally, Lake Merced, also located within City Limits, has an additional approximately 1,000,000,000 gallons. The potable EFWS system for the Westside of San Francisco that is being developed and analyzed would provide that the new EFWS pipeline in the Sunset and Richmond Districts could be supplied from four sources of water at two locations. The first two water sources could be supplied to the EFWS pipeline via a 30,000 gallon per minute pump station in the vicinity of Lake Merced. The two sources being studied for this pump station are Lake Merced, which has a water supply of approximately one billion gallons, and a 60" seismically resilient SPUC Hetch Hetchy Regional Water System pipeline. The proposed potable EFWS also is analyzing the inclusion of a second 30,000 gallons per minute pump station in the vicinity of the SPUC's Sunset Reservoir that could be supplied water by two sources: (1) the 90 million gallon north basin of the Sunset Reservoir, which recently underwent a \$64 million seismic retrofit, and (2) a 54" seismically resilient SPUC Hetch Hetchy Regional Water system pipeline.	R6 [for F8-F9]	The SPUC, the SFD and the SF Department of the Environment should study adding salt-water pump stations to improve the redundancy of water sources, especially on the west side. Findings and recommendations from this study should be presented to the Board of Supervisors by no later than June 30, 2021.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	SPUC and SFD will complete this study by June 30, 2021.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F10	The "reliability scores" being used by the SPUC impart an overly optimistic impression of the protection provided.	Disagree, partially	President, San Francisco Fire Commission [September 15, 2019]	Fire Response Areas (FRAs) were utilized by SPUC and SFD in the planning study CS-199. This study divided the City into areas based on those defined by the SFD for initial alarm response and were called Fire Response Areas (FRAs). Probable fire demands were developed for each FRA using 1000 sets of fire demands generated by Charles Scawthorn, PhD using a Monte Carlo analysis of fire ignitions and fire growth using the ground motions from the design earthquake (7.8 magnitude). The fire ignitions were generated using methods similar to those used for the Community Action Plan for Seismic Safety (CAPSS) study (ATC 2010). The fire ignitions subsequently were used to develop water demands that were aggregated into the likely fire demands for each FRA. The water supplies for each FRA were developed using the reliability modeling tool GIRAFFE, developed at Cornell University by Professor Thomas D. O'Rourke. GIRAFFE performs internal Monte Carlo analysis to damage pipes in the system for multiple scenarios. The water supplies developed by GIRAFFE were aggregated into the likely water supplies for each FRA. It should be noted that the likely water supplies for each FRA assumed no water from the City's municipal water system (MWSS), which is quite conservative and highly unlikely even after a seismic event. The reliability score for each FRA is calculated using the sum of all water supplies for each FRA and dividing it by the FRA water demand. The reliability scores do exactly that - estimate how much EFWS water will be available for firefighting demands in a given FRA. The reliability scores are not meant to represent an estimate of the fire protection for a given house, block, or blocks. Rather it is a measure of the EFWS capacity and demand. The SPUC recognizes the need to analyze potential EFWS demands on a more detailed level, and the agency began the process of doing so.					
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]	F11	The City does not have a timeline to fund and complete development of a high-pressure, multi-sourced, seismically safe emergency water supply for all parts of the City, including poor neighborhoods that historically have not been as well protected as the downtown business district and many richer neighborhoods.	Disagree, partially	President, San Francisco Fire Commission [September 15, 2019]	The EFWS was built after the 1906 earthquake, and its location, primarily in the northeast portion of San Francisco, corresponds to the location of the majority of the city's population at that time. Since 2010, the SPUC, SFD, and Public Works have made critical improvements to the existing EFWS system. Expanding the EFWS prior to ensuring that the existing EFWS is resilient and reliable would have contradicted best engineering practices. The SPUC and SFD are developing plans that would implement a resilient, robust, and redundant potable EFWS for the Westside of San Francisco. The potable EFWS that is being developed and analyzed would propose the best method for bringing a robust and resilient high-pressure firefighting water system to the Western neighborhoods in San Francisco that is capable of providing water to the SFD firefighters at the high-pressure needed for firefighters to combat large fires after a seismic event, and is likely to include over 14 miles of new EFWS pipelines and potentially two new pump stations likely to be supplied by four water sources. The SPUC and SFD's potable EFWS is being designed in a manner that allows for agility and the flexibility to add new technologies and water sources, and in a manner that allows the piping network to be extended in the future to serve additional areas.					

Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]						R9 [for F12]	By no later than December 31, 2020 the SFPUC, with the advice and subject to the approval of the SFD, should (a) implement "best practices" for the maintenance of AWSS assets, and (b) redefine which AWSS valves in the system are "critical," and, therefore, require more attention and priority in the SFPUC's maintenance plans.	President, San Francisco Fire Commission [September 15, 2019]	Has been implemented	(a) SFPUC implements "best practices" for the maintenance of AWSS assets in collaboration with SFD, and consistent with the terms of the Memorandum of Understanding Regarding Operation and Maintenance of San Francisco Water Supply Systems Related to Fire Suppression (MOU). SFPUC will seek SFD's written approval for "any modifications that could compromise" the system's function as a high pressure firefighting system (MOU, page 2). (b) The AWSS critical valves have been identified and will be exercised every year through the AWSS Critical Valve Exercise Program.
Act Now Before It Is Too Late: Aggressively Expand and Enhance Our High-Pressure Emergency Firefighting Water System [July 17, 2019]						R10 [for F13]	By no later than June 30, 2020, the 2015 MOU between the SFPUC and the SFD should be amended to include a detailed roadmap for annual emergency response exercises, including simulated disaster and earthquake drills involving the AWSS and the PWSS.	President, San Francisco Fire Commission [September 15, 2019]	Will be implemented	The Fire Department conducts weekly hose/hose tender drills that it rotates through companies throughout the City. The Fire Department will work with the SFPUC to have them in attendance and participate in these drills. SFD will also commit to working with the PUC to enhance the scope and frequency of trainings in the future for improved collaboration. SFD and SFPUC will work together to amend the MOU by June 30, 2020.